

**14644-16—  
2023**

**16**

**(ISO 14644-16:2019, IDT)**

**2023**

1 « »  
 , 4

2 184 « -  
 »

3 -  
 12 2023 . 224-

4 14644-16:2019 « -  
 . 16.  
 » (ISO 14644-16:2019 «Cleanrooms and associated controlled environments —  
 Part 16: Energy efficiency in cleanrooms and clean air devices», IDT).  
 / 209 «  
 ».

5

29 2015 . 162- « 26  
 ) « ( 1  
 — « »,  
 ( ) « ».  
 ». , —  
 (www.rst.gov.ru)

1	.....	1
2	.....	1
3	.....	1
4	.....	4
5	.....	10
6	.....	10
7	( , ).....	13
8	.....	14
9	.....	15
10	.....	15
11	.....	16
12	.....	16
13	.....	16
14	.....	17
15	.....	17
	( ) : .. 18	
	( ) .....	22
	( ) .....	27
	D ( ) .....	28
	( ) .....	32
	F ( ) .....	33
	( ) .....	34
	.....	35

) (

50001

10

35 % 50 %

80 %

« »

14644-7 [1].

Cleanrooms and associated controlled environments. Part 16.  
Energy efficiency in cleanrooms and clean air devices

— 2024—01—01

**1**

14644 ([2], [3]).

**2**

(Energy management systems. Requirements with guidance for use)

**3**

**3.1**

3.1.1 (air-handling unit, AHU):

3.1.2 (classification):

1 — [ 14644-1:2015, 3.1.4 « »]

3.1.3	(clean air device):	-
(3.1.7)	1 — 14644-7 [1],	-
[ 3.1.4	14644-4:2001, 3.2, (cleanroom):	1] -
1		
2		-
3		-
[ 3.1.5	14644-1:2015, 3.1.1] (clean zone):	-
1		
2		-
3		-
4		-
3.1.6	(pre-filter):	-
[ 3.1.7	14644-4:2001, 3.8] (separative device):	-
1 —		(3.1.5).
2 —		
[ 14644-7:2004, 3.17	— 1	-
1]		
<b>3.2</b>		
3.2.1	(adaptive control):	-
3.2.2	(air change rate):	-
[ 14644-3:2005, 3.4.1,	(3.1.4) (3.1.5).	-
« » « »]		

3.2.3	(diffuser):				
3.2.4	(non-unidirectional airflow; non-UDAF):				
[ 14644-4:2001, 3.6]					
3.2.5	(contaminant removal effectiveness; CRE):				
[ REHVA No. 2]					
3.2.6	(total air volume flow rate):				
[ 14644-3:2005, 3.4.5,	— « » ]				
3.2.7	(air change effectiveness; ):				
	(3.1.4)				
1 —					
3.2.8	(turn-down):				
(3.2.9)	(3.1.4)				
	(3.2.4)				
3.2.9	(unidirectional airflow; UDAF):				
[ 14644-4:2001,3.11,	— 1 « »]				
3.2.10	(emission):				
(3.1.4).					
3.2.11	(source strength):				
3.2.12	(microbe-carrying particle):				
<b>3.3</b>					
3.3.1	(benchmarking):				
3.3.2	(energy cost):				
3.3.3	(power):				
1 —					
[ 14644-7:2004, 3.17,	— 1				
1]					

3.5


CFD —	(computational fluid dynamics);
EMS —	(environmental management system);
FFU —	(fan filter unit);
HSE —	(health, safety and environment);
HVAC —	(heating, ventilation and air conditioning);
RH —	(relative humidity);
SFP —	(specific fan power);
URS —	(user requirement specification)
VE —	(ventilation effectiveness)

4

4.1

1	4.2	4.3,	,	1.	,
			,	2.	-
			,		
			.		





4.2

4.5 4.6

4.3

4.3.1

( 50001).


4.3.2

4.3.3

D.

4.3.4

4.4



: ASPEC-ADEME-EDF «  
)» [5],

(  
ASPEC,

2—

#### 4.5

##### 4.5.1

##### 4.5.2

##### 4.5.3

) ;  
)  
) ;  
) ;  
d) ( ; ) ;  
);

) ;  
f) ;  
);  
h) ;

**4.6**

**4.6.1**

— 5.

**4.6.2**

:  
) ( ;  
);  
) ;

**4.7**

) ( ) (

**4.8**

4.9

), ( ,  
- ;  
- ;  
- ;  
- ;  
- ( );  
- / ;  
-

4.10

(4.9)  
-  
-  
-  
-  
- ( )  
-  
-

4.11

-

4.12

-  
-  
-

4.13

-  
-

**5**

**5.1**

( )

—F

**5.2**

( ).

**6**

**6.1**

**6.2**

[ ( ) ]

)

5  
LILPA

)

6

( 7).

**6.3**

**6.3.1**

D, [7], [8], [9]

.1.

3.

— .2

(ACR) 14644-1 [2].

**6.3.2**

( — CRE) ( ),


s .1). (CFD) ( 3

**6.3.3**


(Cf)

) ) 7 352 000 / 3  
 > 0,5  
 100 000 / 3 50 000 / 3  
 ) 1,0  
 CRE


**Этап 1**



**2**



**3**



-Q -

3 —

**6.4**

**6.4.1**

6.4.2—6.4.3

[10].

6.4

3.

**6.4.2**

$C_{class}$

)  
)  
)



(6.3.1).

$D,$  -

CRE

(6.3.2).

$Q_1$

.1

6.4.3.

6.4.3

$Q_1$

,  $Q_2$  ,

14644-1,

14644-2

14644-3 ([2], [3], [6]),

2

$< C_{class}$ .

6.4.4

$Q_2$

12—14.

[10].

6.5

6.4

.5.

(.5).

0,35 / (

7

( , )

7.1

1 —

).

2 —

7.2

)  
)  
)

8

9

30 % 70 %

10

10.1

80 %.

10 % 15 %

(VSD)

10.2

110  
2,5

( )

40%

66

( ).

Eurovent 4/11 [11]

(LCC)

Eurovent [11].

**11**

**12**

)  
)  
)  
;  
d)  
)

**13**

13.1

( 14644-5 [12]).

13.2

13.3

13.4

13.5

14

14644-5 [12]

14644-2 [3]

(BMS),  
( / )

15

( )

:

.1

:

$$Q = \frac{D}{\epsilon \cdot \dots}, \quad (.1)$$

— ( /<sup>3</sup>);  
 D— ( /);  
 Q— ( ) ( /);  
 ε— ( ).

— .1 « »

(CRE).  
 [7], [8], [9], [13] [14].

D

$$ACR = \frac{3600 \cdot D}{- - V} \quad (.2)$$

ACR— ,<sup>-1</sup>;  
 — ( /<sup>3</sup>);  
 D— ( /);  
 V— ( ).

2 —

.2

.2.1

.1

CRE [4].

.2.2

( ) [18].

ANSI/ASHRAE 129-1997 (RA2002)

[15]

[18]

$$\frac{ACR_m}{ACR_{tot}} \quad ( )$$

$ACR_m$  —  
 $ACR_{tot}$  —

14644-3.

1.

0,7 1,3 ( . Lenegan [16]).

.2.3

(CRE)

(CRE).

$$CRE = \frac{C_{avg}}{avg} \quad ( .4)$$

$C_{avg}$  — / 3;  
 > 0,5  
 > 0,5 / 3.

CRE

[4].

0,3 1,0

.3.1

.3.2

[7], [8].

.4.

**.3.3**

14644-14 [17].

$$= \bullet Q, \quad (.5)$$

— /;  
 — / 3;  
 — , 3/ .

**.4**

3 ( 300 3) 7 , > 0,5 > 5,0 <sup>10 10</sup> . 40 <sup>-1</sup>).

CFD

CFD (

5.1 [5].

- 150 000 / > 0,5  
 - 3 000 / > 5,0 .

**6.4.**

CFD, (.1),

£, 0,7

1,5. = 352 000 / 3 (

> 0,5 ) = 2 930 / 3 ( > 5,0 ), :  
 - Q = 0,61 > 0,5 1,46 > 5 1,5  
 :  
 - 0,93 3/ ( 11 <sup>-1</sup>) > 0,5  
 - 2,2 3/ ( 26 <sup>-1</sup>) > 5,0 .

2,2 3/ ( 1,1 3/ , 6.4). 3,3 3/

**.5**



, . , ,  
:  
) ;  
) ;  
) ;  
) ;  
) ;  
) ;  
) ;

d)

0,2 / — 0,3 /  
( 14644-3) [6].

( )

.1—

-			-	/	- ;	-
-	-	-	( , , - )	-	- ;	5.1.6.9
	-	-	- , -	-	- ,	5.2.6 - F
	-	-	-	-	-	5.2.13
			-	-	-	5.2
	-				-	5.1.9
	-	-	( 14644-14 [17])		-	

-			-	,		5.1 - F
, - -	-		-	,	CFD	6.7.8 -
	-		,	,	CFD	6.7.1
	-	-	,	,		6.10
	-	-		,		6.10
	-	-	,	,		11
	-		-	/		6, - F

£

.1

					CFD	6.7.1
					(NBS)	10
						10
						10.14
	(BMS)			BMS,		14
					CFD	13 14
						8

.1

	,	-	-	-	-	12.6
		-	-	-	-	12.4.12
	-	-	-	-	-	12
	)	-	:	,	-	13.14
	-	-	,	-	-	7.1
		-		-	-	7.2

. 1

		-	-	-	-	14
		-	-	-	-	14
		-	-	-	-	14
( - - )	-	- - / -	- / .	-	- - , )	15

( )

- 1)
- 2)
- 
- 
- 3)

[28].

[19], [20]

( D )

D.1

D

(EnPI)

( )

EnPI.

ASHRAE, EnPI 53, 10 [21], VDI 2083-4.2 [22], BS 8568 [23]

50006 [24].

D.2

14644.

( , RABS,

).

D.3

1)

(PICR):

(EnPI):

( , )

PICR, ( PICR )

(D.4).

2)

(EICR) —

3)

(EI):

(D.4).

50006 [24]

( )

EnPI

D.4

PICR

(PICR)



$$PICR = \frac{Z_p}{\dots} \quad (D.1)$$

$PICR = \dots$   
 $SFP = \dots$   
 $Q_N = \dots$   
 $1^3$   
 $1^2$   
 $(SFP)$   
 $SFP$   
 $SFP$   
 $70-80\%$   
 $\cos \phi$   
 $\cos$   
 $SFP$   
 $3/$

$$SFP = \frac{\dots}{Q} \quad (D.2)$$

$Q = \dots$   
 $SFP = \dots$   
 $3/ ;$   
 $/^3$   
 $« \dots »$   
 $/^3$   
 $SFP$   
 $( \dots )$   
 $SFP$   
 $VSD$   
 $SEP$   
 $Q_N$

$$Q_N \text{-----} Q \tag{D.3}$$

—  
—  
O<sub>N</sub>—

**D.5 (EICR)**

PICR

PICR

EICR.

PICR,

8 760 ( / ) SFP.

EICR.

Q<sub>N</sub> D.4, ),

EICR.

$$SFE = \text{---} \tag{D.4}$$

—  
Q —  
SFE —

SFP

SFE

D.1

EICR

$$EICR = SFE \cdot Q_N \tag{D.5}$$

EICR —

Q<sub>N</sub> —

SFE —

EICR

( , )  
EICR<sub>p,nn</sub>

PICR 8 760 /

EICR

1 2  
E/C/? semicon@ISO6

6

**D.6 — Energy intensity (EI)**

ADEME-EDF (5))

( . ,  
EI

ASPEC-

— 8 760 .

(

-  
-  
).  
-

(

),




( F )


D.

F.1

F.2



F.1 —



F.2 —

( )

.1

ISO 50001	IDT	50001—2012 « - »
<p style="text-align: center;">— :</p> <p>- IDT —</p>		

- [1] ISO 14644-7:2004, *Cleanrooms and associated controlled environments — Part 7: Separative devices (clean air hoods, gloveboxes, isolators and mini-environments)*
- [2] ISO 14644-1:2015, *Cleanrooms and associated controlled environments — Part 1: Classification of air cleanliness by particle concentration*
- [3] ISO 14644-2, *Cleanrooms and associated controlled environments — Part 2: Monitoring to provide evidence of cleanroom performance related to air cleanliness by particle concentration*
- [4] Mundt E., Mathisen H. M., Nielsen P.V., Moser A. REHVA Guidebook No 2: Ventilation Effectiveness, Brussels: Federation of European Heating, Ventilation and Air-conditioning Associations (REHVA). 2004
- [5] ASPEC-ADEME-EDF Guide. Energy performance in clean zones (cleanrooms, Controlled environments, contained areas), France: ASPEC-ADEME-EDF, December 2016
- [6] ISO 14644-3, *Cleanrooms and associated controlled environments — Part 3: Test methods*
- [7] Ljungqvist B. & Reinmuller B. People as contamination Source, Dispersal Chamber Evaluations of Clothing Systems for Cleanrooms & Ultraclean Operating rooms, Gothenburg Sweden: Department of Energy and Environment Chalmers University of Technology, 2014 ref D2014:01
- [8] Romano F., Lungqvist B., Reinmuller B., Gusten J., Joppolo . M. Performance test of technical cleanroom clothing systems, Milan: Dipartimento di Energia, Politecnico di Milano, and Gothenburg Chalmers University of Technology. 2016
- [9] CAMFIL FARR. Clean Room Design Standards and Energy Optimization. Stockholm, Sweden: Camfil Farr, 2012
- [10] Fedotov A. (2016). Air change rates for cleanrooms with non-unidirectional airflow. *Clean Air and Containment Review*, April Issue 26, and 34, pp. 12—20
- [11] EUROVENT. Eurovent 4/11: Energy Efficiency Classification of Air Filters for General Ventilation Purposes, Brussels: Eurovent, 2014
- [12] ISO 14644-5, *Cleanrooms and associated controlled environments — Part 5: Operation*
- [13] Sun W. ed. Development of Cleanroom Required Airflow Rate Model Based on Establishment of Theoretical Basis and Lab Validation. ASHRAE Transactions. Atlanta, GA: ASHRAE. 2010
- [14] White W., Eaton T, Whyte W.M., Lenegan N., Ward S., Agricola K. (2017). Calculation of air supply rates and concentrations of airborne contamination in non-UDAF cleanrooms. *European Journal of Pharmaceutical Sciences*, 22(4), pp. 126—138, <http://eprints.gla.ac.Uk/157532/1/157532.pdf>
- [15] ANSI/ASHRAE Standard 129—1997(RA2022). Measuring air-change effectiveness. American National Standards Institute, USA
- [16] Lenegan N. (2014). Diffuser performance in cleanrooms. *Clean Air and Containment Review*, Issue 18, pp. 8—14
- [17] ISO 14644-14, *Cleanrooms and associated controlled environments — Part 14: Assessment of suitability for use of equipment by airborne particle concentration*
- [18] White W., Ward S., Whyte W.M., Eaton T. (2014). Decay of airborne contamination and ventilation effectiveness of cleanrooms. *International Journal Ventilation*, 13(3) pp. 1—10. Available at <http://eprints.gla.ac.Uk/100819/1/1000819i.pdf>
- [19] INTERNATIONAL CONFERENCE OF HARMONIZATION OF TECHNICAL REQUIREMENTS FOR REGISTRATION OF PHARMACEUTICALS FOR HUMAN USE (ICH). *Quality Guidelines: Q9 Quality Risk Management*. ICH. 2010
- [20] ISO 31000:2018 Risk management — Guidelines
- [21] Mattew P., Tschudi W., Sartor D., Beasley J. Cleanroom energy efficiency: Metrics and Benchmarking. Published in *ASHRAE Journal*, v. 53, issue 10, 2010
- [22] DIN, VDI 2083-4-2-2011, Cleanroom Technology — Energy Efficiency

- [23] BS 8586:2013, Cleanroom Energy — Code of practice for improving energy efficiency in cleanrooms and clean air devices
- [24] ISO 5006, Energy management systems — Measuring energy performance using energy baselines (EnB) and energy performance indicators (EnPI) — General principles and guidelines
- [25] Sun W. Conserving Fan Energy in Cleanrooms. ASHRAE Journal. Atlanta, GA: ASHRAE. 2008
- [26] EN 13053-A1:2011, Ventilation for buildings — Air handling units — Rating and performance for units, components and sections
- [27] AMERICAN SOCIETY OF HEATING, REFRIGERATING AND AIR-CONDITIONING ENGINEERS INC. (ASHRAE) Handbook — HVAC Applications. Chapter 18. Atlanta, Georgia, USA. 2015
- [28] INSTITUTE OF ENVIRONMENTAL SCIENCE AND TECHNOLOGY (IEST). RPCC0112.3: Considerations in Cleanroom Design. Schaumburg, Illinois, USA:IEST. 2015



620.2:006.354

13.040.01  
19.020  
07.030

: , , , , ,  
, ,

13.04.2023.

10.05.2023.

60 841/8.

. . . 4,65. .- . . 4,12.

117418

www.gostinfo.ru info@gostinfo.ru